



ADDENDUM NO. 1 FOR RFQ: STATESVILLE WTP FLOCCULATORS AND FLASH MIXER REPLACEMENT

Project: City of Statesville Public Utilities WTP Division

DATE: March 25, 2025

To: ALL BIDDERS

Bidders for the above-named project shall take note of the following changes, additions, deletions, clarifications, etc., for the Flocculators and Flash Mixer Replacement, please deliver all sealed bids to **City of Statesville at 227 S. Center Street, Basement, Statesville, NC 28677, at or before Friday, April 10, 2026, by 2:00 pm EST. All questions are due by Wednesday, April 1, 2026, by 5pm and all responses will be sent out by Thursday, April 2, 2026, at 12pm.**

Also, as discussed in the pre-bid meeting we will be issuing another addendum soon about the SCADA Integration portion of the project. As stated, it will be a lump sum added to your bid and be paid to our integrator Diversified Integration. The lump sum will just be a pass thru charge to them and will be the same for all bidders.

In order to constitute a complete bid response, bidders must acknowledge receipt of this addendum. **Bidder shall include this addendum in the Bid Package.**

SPECIFICATIONS

Part 1 – General

1.01 THE REQUIREMENT (SCOPE OF WORK)

- E. The Manufacturer shall have a factory authorized service center **close to proximity** to the project location. That is capable of performing, the complete repair of the flocculator and flash mixer units. The service center should have adequate equipment, inventory and personnel to perform repairs and rebuilds to the equipment. The service center shall have complete push-pull equipment and crews which can be onsite with **72** hours of notification. Service centers without in-house push-pull capabilities will not be acceptable.

1.04 QUALITY ASSURANCE SUBMITTALS

- C. Name, contact information and qualifications of the installation contractor. Contractor must demonstrate a minimum of 20 years of experience in installing substantially similar equipment and demonstrate evidence of at least **2** similar installations in satisfactory operation in the last five years in North Carolina. The installation contractor must possess a Public Utilities Contractor's Licenses in North Carolina.

Company Name

Acknowledgement of Receipt (print & sign name)

Date

