



NOTICE OF REQUEST FOR QUOTE FOR A WATER MAIN REPLACEMENT

Sealed bid for replacement of 1200 LF of 2" PVC water main and reconnection of twenty-six (26) water services, will be sent out on **July 22, 2026**, and will be received by the City of Statesville at 1105 Winston Avenue, Statesville, NC 28677 at or before **2:00 p.m.** EST on **Friday, August 28, 2026**, at which time and place the bids shall be publicly opened and read. Minimum of two (2) bids must be received in order to open all bids.

Historically Underutilized Businesses

Pursuant to General Statute 143-48 and Executive Order #150, The City of Statesville invites and encourages participation in this procurement process by businesses owned by minorities, women, disabled, disabled business enterprises and non-profit work centers for the blind and severely disabled.

The website address to view and download the RFQ documentation is: <https://www.statesvillenc.net/bid-postings>

The City of Statesville reserves the right to reject any or all bids and to accept any bid which is deemed to be in the best interest of the City of Statesville. For any questions regarding this request, contact Eric Moten at (704) 832-3823.

B. Denyce Cole
Purchasing Agent

Published: July 20, 2026

City of Statesville Public Utilities Water-Sewer Division Statesville, NC 28677 Refer <u>ALL</u> Inquiries to: Eric Moten Phone #: 704 832-3823	SEALED Request for Quotes: WATER MAIN REPLACEMENT Woodlawn Drive and Forest Drive Sealed Bid Due Date: Friday August 28, 2026, BY 2:00 PM EST Department: Public Utilities Water-Sewer
E-Mail: emoten@statesvillenc.net	

NOTICE TO VENDOR

It is the intent of this bid invitation to obtain proposals for supplying the materials, supplies and/or equipment listed on the Proposal Sheet. You must be in strict compliance with the specifications and offer the same or equal if so quoted. Any additional terms and conditions regarding specifications by the offeror shall have no force or effect.

EXECUTION

In compliance with this Request for Quotes, and subject to all the conditions herein, the undersigned offers and agrees to furnish and deliver any or all items upon which prices are offered, at the prices set opposite each item within the time specified herein.

Failure to execute/sign quote prior to submittal shall render quote invalid. Late quotes are not acceptable.

VENDOR:		PHONE NUMBER:
TYPE OR PRINT NAME & TITLE OF PERSON SIGNING:		FAX NUMBER:
AUTHORIZED SIGNATURE:	DATE:	E-MAIL:

OFFER VALID FOR 30 DAYS FROM DATE OF OPENING.

ACCEPTANCE OF QUOTE

If any or all parts of this quote are accepted, a purchase order will be issued to the vendor within 30 days of quote.

INSTRUCTIONS FOR QUOTES

1. **READ, REVIEW AND COMPLY:** It shall be the offeror's responsibility to read, review and comply with all requirements specified herein.
2. **NOTICE TO OFFERORS:** By execution and delivery of this document, the offeror agrees that any additional terms and conditions, whether submitted purposely or inadvertently, shall have no force or effect.
3. **TIME FOR CONSIDERATION:** Unless otherwise indicated on the first page of this document, the offer shall be valid for 30 days from the date of award.
4. **SPECIFICATIONS:** Any deviation from specifications indicated herein must be clearly pointed out; otherwise, it will be considered that items offered are in strict compliance with these specifications, and offeror will be held responsible, therefore. Deviations shall be explained in detail. **The offeror shall not construe this paragraph as inviting deviation or implying that any deviation will be acceptable.**
5. **CLARIFICATIONS/INTERPRETATIONS:** Any and all questions regarding this document must be addressed to the purchaser named on the cover sheet of this document.

6. **ACCEPTANCE AND REJECTION:** The City of Statesville reserves the right to reject any and all quotes, to waive any informality in quotes and, unless otherwise specified by the offeror, to accept any item in the quote.
7. **HISTORICALLY UNDERUTILIZED BUSINESSES:** Pursuant to General Statute 143-48 and Executive Order #150, The City of Statesville invites and encourages participation in this procurement process by businesses owned by minorities, women, disabled, disabled business enterprises and non-profit work centers for the blind and severely disabled.
8. **AWARD OF CONTRACT:** Qualified quotes will be evaluated and acceptance may be made of the lowest and best quote most advantageous to the City of Statesville as determined upon consideration of such factors as: prices offered; the quality of the articles offered; the substantial conformity with the specifications and other conditions set forth in the quote; the suitability of the items for the intended use; the related services needed; the date or dates of delivery and performance; and such other factors deemed by the City of Statesville to be pertinent or peculiar to the purchase in question. The City of Statesville reserves the right to make partial, progressive, or multiple awards: where it is advantageous to award separately by items; or by purchase and installation; where more than one supplier is needed to provide the contemplated requirements as to quantity, quality, delivery, service, other factors deemed by City of Statesville.
9. **TAXES:**
- Do not include any Federal Excise tax in your quote.
 - The City of Statesville pays sales tax; taxes will not be included on purchase order, but vendor is to bill on invoice.
10. **TERMS AND CONDITIONS:** By bidding of these items, vendor, contractors, and/or subcontractors affirm they have read and accept our Purchasing Terms and Conditions. Our Terms and Conditions can be found at: <https://www.statesvillenc.net/purchasing/>
11. **PRICE INCREASES:** Bidder should consider the manufacturer's pricing at time of bid and quote accordingly. ***If additional costs occur from the time bid is received by the City to the time bidder receives the City's purchase order, the bidder may request a change order for the unforeseen increase.*** The change order request shall include backup documentation showing the date the materials were ordered and a letter from the manufacturer, on the manufacturer's letterhead, indicating the amount and date of price increase. The amount of the change order request shall be limited to the exact amount of increase; profit and overhead expenses will not be accepted.
12. **SUBMITTING REQUEST FOR QUOTES: SEALED BIDS** will be received by the City of Statesville at 301 S Center Street, Basement, Statesville, NC 28677, at or before **Friday, August 28, 2026 by 2:00 pm EST** at which time bids shall be opened and read. A minimum of two (2) bids must be received in order to open all bids. Late bids will not be accepted. Please identify on the envelope that a sealed bid is enclosed.

Bids should be mailed, or hand delivered to:

City of Statesville
Attn: Eric Moten
HAND-DELIVERY: 1105 Winston Avenue
Statesville, NC 28677

If you have any questions about this bid request, please contact Eric Moten at the email address above or call 704 832-3823.

SEALED BID PROPOSAL

Project: Installation of 1,200 LF of 2" PVC Water Main and Reconnection of Sixteen (26) Water Services

Bid Number: _____

Bid Opening Date/Time: _____

Submitted By: _____

Contractor License#: _____

Date: _____

1. PROJECT SUMMARY

The Contractor proposes to furnish all labor, materials, equipment, and incidentals necessary to install approximately 1,200 linear feet of 2-inch PVC water main, reconnect Twenty-six (26) existing water services using Type K copper, and restore all disturbed pavement with 12 inches of ABC stone in 6" lifts compacted, and 3 inches of 9.5 C mix asphalt in 2 1.5 lifts, in accordance with municipal standards and specifications.

2. SCOPE OF WORK

2.1 Water Main Installation

- Install 1,200 LF of 2" PVC water main (Schedule 40/80 or C900 per Owner specification).*
- Provide all fittings, valves, tracer wire, thrust blocks, and appurtenances.*
- Maintain minimum cover and alignment per municipal standards.*
- Perform tie-ins with Owner coordination.*

2.2 Water Service Reconnections

- *Reconnect 26 existing water services using Type K copper.*
- *Install new corporation stops, curb stops, and fittings as required.*
- *Reset meter boxes and ensure proper grade.*
- *Pressure tests all services prior to backfill.*

2.3 Trenching, Backfill, and Pavement Restoration

- *Excavate trench to required depth and width.*
- *Provide bedding and compaction in accordance with municipal standards.*
- *Backfill with 12 inches of ABC stone in 6" lifts.*
- *Restore pavement with 3 inches of 9.5 C mix asphalt in 2- 1.5" lifts (binder/surface per City standard).*
- *Restore all disturbed areas to equal or better condition.*

2.4 Testing and Disinfection

- *Pressure test main and services.*
- *Flush and disinfect main.*
- *Provide test results to Owner.*

2.5 Traffic Control

- *Provide MUTCD-compliant traffic control for the duration of the project.*

3. LINE-ITEM COST TABLE

Item No. Description, Quantity, Unit, Unit Price(\$) and *Total(\$)*

1	Mobilization I Demobilization	1	LS	_____	_____
2	Install 2" PVC Water Main	1,200	LF	_____	_____
3	Fittings, Valves, Appurtenances	1	LS	_____	_____
4	Install Type K Copper Services (Reconnect)	26	EA	_____	_____
5	Corporation Stops / Curb Stops	26	EA	_____	_____
6	Trench Excavation	1,200	LF	_____	_____
7	ABC Stone Backfill(12")	_____	TON	_____	_____
8	Asphalt Pavement (3")	_____	SY	_____	_____
9	Traffic Control	1	LS	_____	_____
10	Pressure Testing & Disinfection	1	IL	_____	_____
TOTAL BID AMOUNT					\$ _____

4. SCOPE DRAWING DESCRIPTION (FOR SUBMITTALS)

Use this in your submittal package to describe the drawing sheet.

4.1 Plan View Description

The scope drawing shall depict:

- *1,200 LF alignment of proposed 2" PVC water main.*
- *Existing roadway, right-of-way limits, and utility corridors*
- *Locations of twenty- six(26) existing water meters to be reconnected.*
- *Proposed service line routes from main to meter boxes.*

- *Locations of valves, fittings, bends, and thrust blocks.*
- *Stationing at 50-foot intervals.*
- *Pavement cut limits and restoration boundaries.*
- *Traffic control zones if applicable.*

4.2 Profile View Description

The profile shall include:

- *Proposed pipe invert elevations.*
- *Minimum cover requirements.*
- *Bedding and backfill notes.*
- *Existing utility crossings (water, sewer, gas, telecom).*
- *High points, low points, and tie-in locations.*

4.3 Detail Sheets

Include:

- *2" PVC main installation detail.*
- *Type K copper service reconnection detail.*
- *Corporation stop and curb stop detail.*
- *Trench section showing, 12" ABC stone and 3" asphalt.*
- *Thrust block detail.*
- *Meter box reset detail.*

5. *BIDDER CERTIFICATION*

The undersigned certifies that this bid is made without collusion, that the Contractor has examined the site and specifications, and that all work will be completed in accordance with municipal standards.

Contractor: _____

Authorized Representative: _____

Signature: _____

Date: _____

Seal (if required)